

TEST REPORT

No.: XMIN2607001789CM02_EN

Issue Date: 2026-08-05

Page: 1 of 4

CUSTOMER NAME: RAMHOUSE, LLC

ADDRESS: RUSSIA, 115487, MOSCOW, NAGATINSKAYA ST., BUILDING 16,
HOUSING 1, CONSTRUCTION 5, ROOM 6H

Sample Name : MSPC Laminate Floor by Stone Floor

Other Information : Product Description: Mineral Stone Polycomposite (MSPC);
Thickness: 8.3+/- 1mm

Above information and sample(s) was/were submitted and confirmed by the client. SGS, however, assumes no responsibility to verify the accuracy, adequacy and completeness of the sample information provided by client.

Sample Source : Customer-delivered

Date of Receipt : 2026-07-22

Testing Period : 2026-07-22 ~ 2026-08-05

Test result(s) : For further details, please refer to the following page(s)
(Unless otherwise stated the results shown in this test report refer only to the sample(s) tested)

Signed for and on behalf of
SGS-CSTC Standards Technical Services Co.,Ltd. Xiamen Branch



Bryan Hong

Authorized signatory



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No.31 Xianghong Road, Xiang'an Torch Industrial Zone, Xiamen, Fujian Province, China 361101
中国·福建·厦门·火炬(翔安)产业区翔虹路31号 邮编: 361101

t (86-592) 5765857 www.sgsgroup.com.cn
t (86-592) 5765857 sgs.china@sgs.com

Scan to see the report



XMIN2607001789CM02
Verification:
check.sgschina.com.cn

TEST REPORT

No.: XMIN2607001789CM02_EN


Issue Date: 2026-08-05

Page: 2 of 4

Summary of Results:

No.	Test Item	Test Method	Result
1	Behaviour at Chemical Influence	Refer to DIN 68861-1:2011-01 & DIN EN 12720:2009-07	See result

Original Sample Photo:



SGS-CSTC Standards Technical Services Co., Ltd.
Xiamen Branch

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No.31 Xianghong Road, Xiang'an Torch Industrial Zone, Xiamen, Fujian Province, China 361101
中国·福建·厦门·火炬(翔安)产业区翔虹路31号 邮编: 361101

t (86-592) 5765857 www.sgsgroup.com.cn
t (86-592) 5765857 sgs.china@sgs.com

Member of the SGS Group (SGS SA)

TEST REPORT

No.: XMIN2607001789CM02_EN

Issue Date: 2026-08-05

Page: 3 of 4

1. Test Item: Behaviour at Chemical Influence

Sample Description: See photo

Test Method: Refer to DIN 68861-1:2011-01 & DIN EN 12720:2009-07

Test Condition:

Specimen: 100mm×100mm, 24pcs

Test Result:

No.	Stain agent	Contact time (1A)	Result (Index)
1	Acetic acid (10%)	16h	Rating 5
2	Citric acid (10%)	16h	Rating 5
3	Ammonia solution (10%)	16h	Rating 5
4	Ethanol (48%)	16h	Rating 5
5	Red wine	16h	Rating 5
6	Beer	16h	Rating 5
7	Cola	16h	Rating 5
8	Coffee	16h	Rating 5
9	Black tea	16h	Rating 5
10	Black currant juice	16h	Rating 5
11	Condensed milk	16h	Rating 5
12	Water	16h	Rating 5
13	Cleaning benzine	16h	Rating 5
14	Acetone	16h	Rating 5
15	Ethyl acetate and butyl acetate	16h	Rating 5
16	Butter	16h	Rating 5
17	Olive oil	16h	Rating 5
18	Mustard	16h	Rating 5
19	Onions	16h	Rating 5
20	Disinfectants	16h	Rating 5
21	Black ball point pen paste ink	16h	Rating 5
22	Endorsing ink	16h	Rating 5
23	Cleaning agents	16h	Rating 5
24	Cleaning solution	16h	Rating 5



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS-CTC (Shanghai) Technical Services Co., Ltd.
Xiamen Branch

No.31 Xianghong Road, Xiang'an Torch Industrial Zone, Xiamen, Fujian Province, China 361101
中国·福建·厦门·火炬(翔安)产业区翔虹路31号 邮编: 361101

t (86-592) 5765857 www.sgsgroup.com.cn
t (86-592) 5765857 sgs.china@sgs.com

TEST REPORT

No.: XMIN2607001789CM02_EN

Issue Date: 2026-08-05

Page: 4 of 4

Note: According to DIN EN 12720:2009-07 Table 2, rating 5 is the best and rating 1 is the worst.

Numerical rating	Description
5	No change test area indistinguishable from adjacent surrounding area
4	Minor change test area distinguishable from adjacent surrounding area, only when the light source is mirrored on the test surface and is reflected towards the observer's eye, e. g. discoloration, change in gloss and colour no change in the surface structure, e.g. swelling, fibre raising, cracking, blistering
3	Moderate change test area distinguishable from adjacent surrounding area, visible in several viewing directions, e. g. discoloration, change in gloss and colour no change in the surface structure, e.g. swelling, fibre raising, cracking, blistering
2	Significant change test area clearly distinguishable from adjacent surrounding area, visible in all viewing directions, e. g. discoloration, change in gloss and colour, and / or structure of the surface slightly changed, e.g. swelling, fibre raising, cracking, blistering
1	Strong change the structure of the surface being distinctly changed and / or discoloration, change in gloss and colour, and / or the surface material being totally or partially removed, and / or the filter paper adhering to the surface

*****End of report*****



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No.31 Xianghong Road, Xiang'an Torch Industrial Zone, Xiamen, Fujian Province, China 361101
中国·福建·厦门·火炬(翔安)产业区翔虹路31号 邮编: 361101

t (86-592) 5765857 www.sgsgroup.com.cn
t (86-592) 5765857 sgs.china@sgs.com